

Portable Appliance Test Certificates

The following lists all items that have been inspected and tested to the required standard for portable appliances with the following test standards and results recorded at the time of the test by a person suitably qualified to test and inspect portable appliances on a high quality industry recognised and calibrated test instrument.

Test machine used: Seaward Apollo 400 32H-0709 Calibrated until: 01/12/2017

All listed items have been certified PASSED on behalf of the following client, by: **PAT4MUSIC** certified

RA17RandomActs

4 Hailing Mews
21 Wendover Road
Bromley
BR2 9JU

ashleydudman@yahoo.co.uk

Andy Blake/Ash Dudman andyblake75@hotmail.com

Test No: 5887 Date: 19/04/2017 Test by: Clive Gregory (Appliance ID, date and initials should match details on appliance label)
Certificate period: 12 months Re-test date: 19/04/2018 Risk type LR
APPLIANCE ID: RA17 01 Initials: C.G. type and class Audio (IT) CI:1

Location	Test ref:	Make	Model	Description	Serial No:
Music Equipment	1452	Peavey	XM6	Mixer amplifier	

Test Results

Reading:	Test setting:	Unit:	Test setting/limit/unit:	Result:	Status:
Visual:	Plug, case, cable (as applicable)			PASS	PASS
Earth bond:	0.2	A	0.139 ohm	0.12 ohm	PASS
Insulation:	250	volts	1 Mohm	19.99 Mohm	PASS
Leakage:	250	volts	3.5 mA	0.04 mA	PASS
Load:	250	volts		0.05 kVA	PASS
Touch Leakage:		volts	volts	volts	
Polarity:				N/A	N/A

Test No: 5888 Date: 19/04/2017 Test by: Clive Gregory (Appliance ID, date and initials should match details on appliance label)
Certificate period: 12 months Re-test date: 19/04/2018 Risk type LR
APPLIANCE ID: RA17 02 Initials: C.G. type and class Extension reel CI:1

Location	Test ref:	Make	Model	Description	Serial No:
Music Equipment	1453	Unknown	Extension reel	x4 10m 13A	

Test Results

Reading:	Test setting:	Unit:	Test setting/limit/unit:	Result:	Status:
Visual:	Plug, case, cable (as applicable)			PASS	PASS
Earth bond:	0.2	A	0.256 ohm	0.18 ohm	PASS
Insulation:	250	volts	1 Mohm	19.99 Mohm	PASS
Leakage:		volts	mA	mA	N/A
Load:		volts			N/A
Touch Leakage:		volts	volts	volts	
Polarity:				PASS	PASS

RA17RandomActs

4 Hailing Mews
21 Wendover Road
Bromley
BR2 9JU

ashleydudman@yahoo.co.uk

Andy Blake/Ash Dudman andyblake75@hotmail.com

Test No: 5889 Date: 19/04/2017 Test by: Clive Gregory *(Appliance ID, date and initials should match details on appliance label)*
Certificate period: 12 months Re-test date: 19/04/2018 Risk type LR
APPLIANCE ID: RA17 03 Initials: C.G. type and class Extension lead CI:1

Location	Test ref:	Make	Model	Description	Serial No:
Music Equipment	1454	Unknown	Extension block	x4 0.3m 13A	

Test Results

Reading:	Test setting:	Unit:	Test setting/limit/unit:	Result:	Status:
Visual:	<i>Plug, case, cable (as applicable)</i>			PASS	PASS
Earth bond:	0.2	A	0.105 ohm	0.03 ohm	PASS
Insulation:	250	volts	1 Mohm	19.99 Mohm	PASS
Leakage:		volts	mA	mA	N/A
Load:		volts			N/A
Touch Leakage:		volts	volts	volts	
Polarity:				PASS	PASS

Test No: 5890 Date: 19/04/2017 Test by: Clive Gregory *(Appliance ID, date and initials should match details on appliance label)*
Certificate period: 12 months Re-test date: 19/04/2018 Risk type LR
APPLIANCE ID: RA17 04 Initials: C.G. type and class IEC lead CI:1

Location	Test ref:	Make	Model	Description	Serial No:
Music Equipment	1455	Unknown	IEC	2m 6A	

Test Results

Reading:	Test setting:	Unit:	Test setting/limit/unit:	Result:	Status:
Visual:	<i>Plug, case, cable (as applicable)</i>			PASS	PASS
Earth bond:	0.2	A	0.152 ohm	0.09 ohm	PASS
Insulation:	250	volts	1 Mohm	19.99 Mohm	PASS
Leakage:		volts	mA	mA	N/A
Load:		volts			N/A
Touch Leakage:		volts	volts	volts	
Polarity:				PASS	PASS

Test No: 5891 Date: 19/04/2017 Test by: Clive Gregory *(Appliance ID, date and initials should match details on appliance label)*
Certificate period: 12 months Re-test date: 19/04/2018 Risk type LR
APPLIANCE ID: RA17 05 Initials: C.G. type and class IEC lead CI:1

Location	Test ref:	Make	Model	Description	Serial No:
Music Equipment	1456	Unknown	IEC	2m 6A	

Test Results

Reading:	Test setting:	Unit:	Test setting/limit/unit:	Result:	Status:
Visual:	<i>Plug, case, cable (as applicable)</i>			PASS	PASS
Earth bond:	0.2	A	0.152 ohm	0.08 ohm	PASS
Insulation:	250	volts	1 Mohm	19.99 Mohm	PASS
Leakage:		volts	mA	mA	N/A
Load:		volts			N/A
Touch Leakage:		volts	volts	volts	
Polarity:				PASS	PASS

RA17RandomActs

4 Hailing Mews
21 Wendover Road
Bromley
BR2 9JU

ashleydudman@yahoo.co.uk

Andy Blake/Ash Dudman andyblake75@hotmail.com

Test No: 5892 Date: 19/04/2017 Test by: Clive Gregory (Appliance ID, date and initials should match details on appliance label)
Certificate period: 12 months Re-test date: 19/04/2018 Risk type LR
APPLIANCE ID: RA17 06 Initials: C.G. type and class PSU Cl:2

Location	Test ref:	Make	Model	Description	Serial No:
Music Equipment	1457	Line 6	RH48T	PSU	

Test Results

Reading:	Test setting:	Unit:	Test setting/limit/unit:	Result:	Status:
Visual:	<i>Plug, case, cable (as applicable)</i>			PASS	PASS
Earth bond:		A	ohm	ohm	N/A
Insulation:	250	volts	2 Mohm	19.99 Mohm	PASS
Leakage:	250	volts	0.25 mA	0.01 mA	PASS
Load:	250	volts		0.05 kVA	PASS
Touch Leakage:		volts	volts	volts	
Polarity:				N/A	N/A

Test No: 5893 Date: 19/04/2017 Test by: Clive Gregory (Appliance ID, date and initials should match details on appliance label)
Certificate period: 12 months Re-test date: 19/04/2018 Risk type LR
APPLIANCE ID: RA17 07 Initials: C.G. type and class PSU Cl:2

Location	Test ref:	Make	Model	Description	Serial No:
Music Equipment	1458	Unknown	E	PSU	

Test Results

Reading:	Test setting:	Unit:	Test setting/limit/unit:	Result:	Status:
Visual:	<i>Plug, case, cable (as applicable)</i>			PASS	PASS
Earth bond:		A	ohm	ohm	N/A
Insulation:	250	volts	2 Mohm	19.99 Mohm	PASS
Leakage:	250	volts	0.25 mA	0.01 mA	PASS
Load:	250	volts		0.05 kVA	PASS
Touch Leakage:		volts	volts	volts	
Polarity:				N/A	N/A

Test No: 5894 Date: 19/04/2017 Test by: Clive Gregory (Appliance ID, date and initials should match details on appliance label)
Certificate period: 12 months Re-test date: 19/04/2018 Risk type LR
APPLIANCE ID: RA17 08 Initials: C.G. type and class PSU Cl:2

Location	Test ref:	Make	Model	Description	Serial No:
Music Equipment	1459	Unknown	Lavolta	PSU	

Test Results

Reading:	Test setting:	Unit:	Test setting/limit/unit:	Result:	Status:
Visual:	<i>Plug, case, cable (as applicable)</i>			PASS	PASS
Earth bond:		A	ohm	ohm	N/A
Insulation:	250	volts	2 Mohm	19.99 Mohm	PASS
Leakage:	250	volts	0.25 mA	0.01 mA	PASS
Load:	250	volts		0.05 kVA	PASS
Touch Leakage:		volts	volts	volts	
Polarity:				N/A	N/A

RA17RandomActs

4 Hailing Mews
21 Wendover Road
Bromley
BR2 9JU

ashleydudman@yahoo.co.uk

Andy Blake/Ash Dudman andyblake75@hotmail.com

Test No: 5895 Date: 19/04/2017 Test by: Clive Gregory *(Appliance ID, date and initials should match details on appliance label)*
Certificate period: 12 months Re-test date: 19/04/2018 Risk type LR
APPLIANCE ID: RA17 09 Initials: C.G. type and class PSU Cl:2

Location	Test ref:	Make	Model	Description	Serial No:
Music Equipment	1460	Unknown	AC/DC	Adaptor PSU	

Test Results

Reading:	Test setting:	Unit:	Test setting/limit/unit:	Result:	Status:
Visual:	<i>Plug, case, cable (as applicable)</i>			PASS	PASS
Earth bond:		A	ohm	ohm	N/A
Insulation:	250	volts	2 Mohm	19.99 Mohm	PASS
Leakage:	250	volts	0.25 mA	0.01 mA	PASS
Load:	250	volts		0.05 kVA	PASS
Touch Leakage:		volts	volts	volts	
Polarity:				N/A	N/A

Test No: 5896 Date: 19/04/2017 Test by: Clive Gregory *(Appliance ID, date and initials should match details on appliance label)*
Certificate period: 12 months Re-test date: 19/04/2018 Risk type LR
APPLIANCE ID: RA17 10 Initials: C.G. type and class Lighting (IT) Cl:1

Location	Test ref:	Make	Model	Description	Serial No:
Music Equipment	1461	Stairville	parcan	LED light	

Test Results

Reading:	Test setting:	Unit:	Test setting/limit/unit:	Result:	Status:
Visual:	<i>Plug, case, cable (as applicable)</i>			PASS	PASS
Earth bond:	0.2	A	0.126 ohm	0.12 ohm	PASS
Insulation:	250	volts	1 Mohm	19.99 Mohm	PASS
Leakage:	250	volts	3.5 mA	0.03 mA	PASS
Load:	250	volts		0.05 kVA	PASS
Touch Leakage:		volts	volts	volts	
Polarity:				N/A	N/A

Test No: 5897 Date: 19/04/2017 Test by: Clive Gregory *(Appliance ID, date and initials should match details on appliance label)*
Certificate period: 12 months Re-test date: 19/04/2018 Risk type LR
APPLIANCE ID: RA17 11 Initials: C.G. type and class Lighting (IT) Cl:1

Location	Test ref:	Make	Model	Description	Serial No:
Music Equipment	1462	Stairville	parcan	LED light	

Test Results

Reading:	Test setting:	Unit:	Test setting/limit/unit:	Result:	Status:
Visual:	<i>Plug, case, cable (as applicable)</i>			PASS	PASS
Earth bond:	0.2	A	0.126 ohm	0.12 ohm	PASS
Insulation:	250	volts	1 Mohm	19.99 Mohm	PASS
Leakage:	250	volts	3.5 mA	0.03 mA	PASS
Load:	250	volts		0.05 kVA	PASS
Touch Leakage:		volts	volts	volts	
Polarity:				N/A	N/A